


RCP LEGEND



CEILING TYPES

TYPE	DESCRIPTION	HEIGHT
ACT-1	2x4 ACOUSTIC TILE, 15/16" GRID, NRC 0.70, WHITE	9'-0" UNO
ACT-2	2x4 VINYL-FACED WASHABLE TILE, CLEAN-ROOM GRID	9'-0" UNO
GWB-1	50" GWB ON 78" FURRING, LEVEL 4, PAINT P-1	8'-0"
GWB-2	50" MR GWB, LEVEL 4, EPOXY PAINT P-3	8'-0"
EXP	EXPOSED STRUCTURE, PAINT P-4	-
EXIST.	EXISTING CEILING TO REMAIN, PATCH AS REQUIRED	-

LIGHT FIXTURE SCHEDULE

TYPE	DESCRIPTION	MANUFACTURER / SERIES	LAMP	WATTS	MOUNTING	REMARKS
A	2x4 LED VOLUMETRIC TROFFER, 4000 LM	LITHONIA 2BLT4 40L	LED 4000 K	32	RECESSED	0-10 V DIMMING; OCCUPANCY SENSOR PER E-201
B	6" LED DOWNLIGHT, 1500 LM, WET LABEL	GOTHAM EVOS	LED 3500 K	15	RECESSED	CORRIDOR AND RESTROOMS
C	EXAM LIGHT, CEILING MOUNTED ARM	BURTON ARM LED	LED 4500 K	26	SURFACE	OFCI BLOCKING PER KEYNOTE B, A-101
D	SURGICAL / PROCEDURE LIGHT	SKYTREN STELLAR	LED	60	SURFACE	OFCI PROCEDURE 118 ONLY
E	2" LED STRIP, WRAP LENS	LITHONIA ZLIN	LED 4000 K	18	SURFACE	ELEC / MECH 111
X	EXIT SIGN, EDGE-LIT, BATTERY BACKUP	LITHONIA EDG	LED	2	CEILING	ARROWS AS SHOWN, 90 MIN BATTERY

REFLECTED CEILING PLAN NOTES

- CENTER ALL FIXTURES, DIFFUSERS AND SPRINKLER HEADS IN TILES UNLESS NOTED OTHERWISE.
- COORDINATE CEILING HEIGHTS WITH MECHANICAL DUCTWORK, ESPECIALLY THE SUPPLY TRUNK AT CORRIDOR 100 BETWEEN GRIDS C AND D.
- PROVIDE SEISMIC BRACING OF SUSPENDED CEILINGS PER ASTM F596 AND 0505C 1813.
- SUPPORT ALL LIGHT FIXTURES INDEPENDENTLY OF THE CEILING GRID WITH TWO SLACK SAFETY WIRES MINIMUM.
- EXAM LIGHTS AND THE PROCEDURE LIGHT ARE OWNER FURNISHED. CONTRACTOR INSTALLED (OFCI); PROVIDE UNDISTURB BLOCKING TO STRUCTURE.
- WADING 121: NO PENETRATIONS THROUGH THE LEAD-LINED CEILING ZONE WITHOUT PHYSICIST REVIEW.
- RESTROOM CEILINGS: MOISTURE RESISTANT GWB WITH ACCESS PANELS AT VALVES, SEE P-201.
- FOR LIGHTING CIRCUITS AND CONTROLS SEE E-201. FOR DIFFUSER SIZES AND ARRAYS SEE M-201.
- MAINTAIN 18" CLEAR BELOW SPRINKLER DEFLECTORS. RELOCATE EXISTING HEADS TO SUIT THE NEW LAYOUT. SUBMIT HYDRAULIC CALCULATIONS.



STUDIO MERIDIAN

ARCHITECTS

1212 NW Hoyt Street, Suite 400
Portland, Oregon 97209 503.555.0142

studiomerdian.example

Oregon Reg. No. 7421

CONSULTANTS

STRUCTURAL Cascade Structural Engineers, PC
MECH / PLUMB Williams Mechanical Group
ELECTRICAL Northwest Electrical Design, LLC
CNVL Riverside CHL, Inc.
LANDSCAPE Terra Firma Studio


PROJECT

RIVERSIDE CLINIC
TENANT IMPROVEMENT

4120 SE River Road
Portland, Oregon 97202

OWNER Riverside Health Partners, LLC
PROJECT NO. 1436.01
PERMIT NO. 26-118442-000-00-CO
BLDG TYPE II-B OCC. B (AMB. CARE)
AREA OF WORK 10,080 SF
SPRINKLERED YES (EXISTING, NFPA 13)

PROFESSIONAL SEAL




REVISIONS

NO.	DATE	DESCRIPTION
1	08/22/26	PERMIT SET
2	09/18/26	PERMIT CORRECTIONS

ISSUE

DATE 10/02/2026
DRAWN TK
CHECKED JRA
APPROVED JRA
SCALE 1/8" = 1'-0"

KEY PLAN



AREA OF WORK (HATCHED) - LEVEL 1

SHEET TITLE

REFLECTED
CEILING PLAN

ARCHITECTURAL

SHEET NUMBER

A-121

SHEET 8 OF 38

© 2026 Studio Meridian Architects. All rights reserved.